

WINDOW & SILL FINISH MATERIAL PER BUILDING & MANUFACTURER'S SPECS

1/4"Ø STAINLESS STEEL WOOD SCREWS TO PENETRATE NO LESS THAN 1 1/2" INTO BACKING WALL FRAMING

BRACKETS TO BE FASTENED TO FRAME WITH 1/4"Ø STAINLESS STEEL WOOD SCREWS

BUILDING WRAP INSTALLED OVER STRUCTURAL PANEL BOARD SHEATHING

WOOD FRAME BACKING WALL TO COMPLY w/ APPLICABLE PROVISIONS OF SECTION 2308 OF IBC & LOCAL BUILDING CODES

FTS SUPPORT BRACKET

BRACKETS TO BE SECURED TO SPRUCE, PINE, OR FIR SPECIES WOOD FRAME WITH SPECIFIC GRAVITY OF NOT LESS THAN 0.42

PROVIDE FLASHING BEHIND WINDOW FLANGE & OVER TOP OF FTS TOP RECEIVER BRACKET & OVER TOP FRONT EDGE OF STONE VENEER PANEL

FTS TOP RECEIVER BRACKET

FTS SUPPORT CLIP

SPACERS TO BE INSTALLED AT ALL FASTENERS BETWEEN BACK OF BRACKET & FACE OF WALL SHEATHING SURFACE SERVING AS DRAINAGE PLANE

VARIES

FOR TYPICAL 3/8" MASONRY JOINTS INSTALL 1/2"Ø BACKER ROD SET 3/16" INTO PANEL JOINTS w/ SEALANT APPLIED OVER ROD & BETWEEN PANEL EDGES

FASTENERS TO BE INSTALLED A MINIMUM OF 3/8" FROM TOP & BOTTOM BRACKET EDGES & A MINIMUM OF 1" FROM BRACKETS ENDS AT A MAXIMUM HORIZONTAL SPACING OF 18" APART

2 7/8" TYPICAL

ALTERNATIVE WINDOW SILL B SECTION VIEW

SCALE: 3"=1'-0"

DATE: 5-2-11

DRAWN BY: B. CARTER

JOB NO.: RC-028-11

PROJ.: FTS WOOD DET.S SHEET: 17 OF 30

ACAD FILE: FTS-A001.DWG

FAST TRACK STONE SYSTEM™

Innovative Building Products, Inc. • P.O. Box 425 Fort Worth, TX 76101
Phone: (800) 932-2263 • Fax: (817) 332-1406
Plant • 206 Dotson St. Denton, TX 76205